



OUTLINE AS PER SPECIFICATION: CSA C2.1-06



|          |
|----------|
| kVA: 500 |
|          |

|            |      |
|------------|------|
| MASS (kg): | 2350 |
| OIL (LI.): | 656  |

| IT | DESCRIPTION                        |
|----|------------------------------------|
| 1  | Low-voltage terminals              |
| 2  | High-voltage terminals (#8 to 4/0) |
| 3  | Cover                              |
| 4  | Lifting lugs                       |
| 5  | Tank grounding terminal (SS)       |
| 6  | Low-voltage neutral terminal (SS)  |
| 7  | Cover bonding strap                |
| 8  | Drain valve                        |
| 9  | Non-PCB sticker                    |
| 10 | Nameplate                          |
| 11 | Voltage selector                   |
| 12 | Tap changer                        |
| 13 | Liquid level gauge                 |
| 14 | Thermometer                        |
| 15 | Pressure relief valve              |
| 16 | Radiator                           |
| 17 | Oil filler plug (1" NPT)           |



DETAIL A  
Tank grounding terminal (S.S.)



## REVISIONS

**SIEMENS**  
energy

Siemens Énergie Transformateurs Canada Inc.  
Siemens Energy Transformers Canada Inc.

DATE  
2022-05-19

CH/VER

|                  |
|------------------|
| DWN/DESS         |
| Maxime Pomerleau |

|     |
|-----|
| APP |
|-----|

A- 661 455 015

REV.  
00

Note: All dimensions are in millimeters

TR3420